



CERTIFICATE OF ANALYSIS

L8G1346

Dry Ridge, City of
Robbie Bosse
31 Broadway
Dry Ridge, KY 41035

Date Reported 07/26/2018
Date Due 08/02/2018
Date Received 07/24/2018
Customer # E6072

WTP - Total Coliforms

Analysis	OOB	Qualifier	Result	Units	Min	Max	Method	Rpt Limit	Analysis Date	Tech
Sample: 01 31 Broadway										
Sampled By Customer										
Location Code 001										
DWSampleType RT										
WSF ID 0410107DS001										
Plant ID NA										
PWS Name Dry Ridge, City of										
Chlorine, Free Available			0.80	mg/L			CLIENT SPECIFIED	0.02	07/24/2018 13:15	CUS
Coliforms and E. Coli - DW							SM9223B (Colilert-18)			
Coliform, Total			Absent	per 100mL				1	07/24/2018 16:34	CDW

Qualifier Definitions

The following analyses were subcontracted to a qualified laboratory:

Laboratory	Analysis	Method
Lexington	Coliforms and E. Coli - DW	SM9223B (Colilert-18)

Project Requested Certification(s):

Certificate ID	Agency
00040	Kentucky Drinking Water Accreditation

THIS REPORT HAS BEEN REVIEWED AND APPROVED FOR RELEASE:

Anne Daniels A.M.

Samples were received in proper condition and the reported results conform to applicable accreditation standard unless otherwise noted.

The data and information on this, and other accompanying documents, represents only the sample(s) analyzed. This report is incomplete unless all pages indicated in the footnote are present and an authorized signature is included.

The data and other information contained on this, and other accompanying documents, represents only the sample(s) analyzed and is rendered upon the condition that it is not to be reproduced wholly or in part for advertising or other purposes without written approval from the laboratory.

Microbac Laboratories, Inc.

3323 Gilmore Industrial Blvd. Louisville, KY 40213 502.962.6400 Fax: 502.962.6411
Evansville 812.464.9000 | Lexington 859.276.3506 | Paducah 270.898.3637 | Hazard 606.487.0511



TOTAL COLIFORM CHAIN OF CUSTODY

Microbac Laboratories, Inc. - Kentucky Testing Laboratory Division - www.microbac.com
Louisville 502-962-6400 • Lexington 859-276-3506 • Paducah 270-898-3637 • Hazard 606-487-0511 • Evansville, IN 812-464-9000

WS #: KY 0410107

Client: CITY OF DRY RIDGE

P.O. BOX 145

DRY RIDGE, KY 41035

Collo Bane

Samples Collected by (Signature):

emp. Upon Receipt in Lab (°C):

5.8 Infrared Therm. ID: L-10

Rec. on Ice (Y/N): YES

Bottle Type: 120 mL plastic with Sodium Thiosulfate

Sample Volume: 100 mLs

Relinquished by (Signature):

Collo Bane

Received by (Signature):

Ray Hays

Relinquished by (Signature):

Ran Hays

Received by (Signature):

Collo Bane

Phone No.:

Fax No.:

Special Instructions:

Shipped to Lab Via (if applicable): UPS Acceptable Not Acceptable Other

Condition of Sample(s) Upon Receipt: 1 Acceptable Not Acceptable

samples relinquished: 1 Date: 07-24-18 Time: 1:25

samples received: 1 Date: 07-24-18 Time: 1:25

samples relinquished: 1 Date: 07-24-18 Time: 14:00

samples received: 1 Date: 07-24-18 Time: 14:40

No.	Location Code	*	Location	Replacement (Y or N)	Collection		Special Sample Reason	Disinfectant Residual		
					Date	Time		Type	Total	Free
001	001		31 Broadway	N	07-24-2018	13:15	BT	3	90	80
002										
003										
004										
005										
006										
007										
008										
009										
010										

Reason for Sample Rejection:

* OR - Original
DN - Down
UP - Upstream

Sample Type: RT - Routine
SP - Special
RP - Repeat

Special Sample Reason: A - Suspected contamination
B - New plant modification; Line ext.
C - Treatment modification

D - Study/Investigation
E - Line Break

Disinfectant Type: 1 - Chlorine
2 - Chloramines
3 - Chlorine Dioxide
4 - Ozone

Analysis: TC - Total Coliform